



AIRFLOWS TESTED BY C.S.I.R.O. TO BRITISH STANDARD BS848

MODEL NUMBER	HEAT INPUT MJ/H	HEAT OUTPUT KW		AIR FLOW (l/s AT 75Pa ESP)		WEIGHT KG	POWER SOURCE VOLTS/PH/Hz	CONTROL VOLTAGE VAC	CURRENT AMPS TOTAL/FLA/LFC	NOM. COOLING Kw (Sensible /Total)	A	B	C	D	E
		HIGH	LOW	HIGH	LOW										
EX2-90S	90	18.8	600	500	150	240/1/50	24	15/12/45	4.8/6.5	1690	500	1115	200	350	
EX3.5-90S	90	18.8	700	540	170	240/1/50	24	22/19/40	7.5/10	1690	500	1115	200	350	
EX4-120S	120	25	870	700	200	240/1/50	24	26/19.6/42	9/12	1690	760	1270	200	400	
EX5-120S	120	25	870	700	208	240/1/50	24	28/20.4/45	10.8/14.4	1690	760	1270	200	400	
EX5-150S	150	32	1000	740	220	240/1/50	24	28/20.4/45	10.8/14.4	1690	760	1270	200	400	
EX5-120T	120	25	870	700	208	4 15/3/50	24	12/PH/8.6/56	12.6/15.5	1690	760	1270	200	400	
EX5.75-150T	150	32	1000	740	220	4 15/3/50	24	12/PH/10/60	14.5/18	1690	760	1270	200	400	